

## ARIZONA WATER COMPANY WATER METER INSTALLATION CHECKLIST

Prior to installation of the meter, the property must meet the following:

1. The property has final acceptance of the water facilities, including service line, meter box and related fittings.
2. Parcel Name, lot and address is clearly posted in front of the premises, provide a photo with your application to request water service.
3. All lot grading must be within six (6) inches of final grade.
4. Meter box must be unbroken (with lid), level and adjusted to final grade.
5. Meter box must be free of all dirt and debris, unobstructed, and accessible.
6. Customer shall provide and maintain a private cutoff valve within 18-inches of the meter on the Customer's side of the meter in accordance with AAC R14-2-405.B.3.
7. Backflow device, if required, must be installed prior to meter installation.
8. Customer has completed Application to Request Water Service to establish water account with the local division office.

