

ARIZONA WATER COMPANY

- 2024 ANNUAL WATER QUALITY REPORT FOR WHITE TANK, ARIZONA, PWSID NO. 07-128 -

This report contains important information about your drinking water.

Este informe contiene información importante sobre su agua potable.

Tradúzcalo o hable con alguien que lo entienda bien, o visita:

<https://espanol.epa.gov/espanol/recursos-e-informacion-sobre-el-ccr-para-los-consumidores>

Arizona Water Company provides its White Tank customers groundwater from wells located throughout the White Tank area and surface water from the Colorado River transported through the Central Arizona Project canal system and treated at EPCOR's White Tank Treatment Facility. For more information you can view EPCOR's Agua Fria District Water Quality Report at this website: <https://www.epcor.com/products-services/water/water-quality/water-quality-reports-usa/Pages/water-quality-reports-agua-fria.aspx>.

All water samples are collected by state-certified employees of Arizona Water Company. Samples are analyzed by state-certified independent laboratories and the results are forwarded to the Arizona Department of Environmental Quality ("ADEQ"). The following report provides detailed information about the quality of the water delivered to customers. The water supplied by Arizona Water Company complies with all state and federal safe drinking water standards and regulations.

DETECTED WATER QUALITY CONSTITUENTS - GROUNDWATER AND SURFACE WATER

Primary Standards						
Water Quality Constituent	Units	MCLG	MCL	Range of Levels Detected	Sample Year	Typical Source of Detected Constituent
Antimony*	ppb	6	6	ND - 0.5	2024	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder
Arsenic*	ppb	0	10	ND - 7.4	2024	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
				HLRAA - 7		
Barium*	ppm	2	2	ND - 0.24	2024	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Chromium, Total*	ppb	100	100	ND - 66	2024	Discharge from steel and pulp mills; erosion of natural deposits
Fluoride*	ppm	4	4	ND - 2.6	2024	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Nitrate (as Nitrogen)*	ppm	10	10	ND - 5.6	2024	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Selenium*	ppb	50	50	ND - 3.9	2024	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Sodium *	ppm	NS	NS	58 - 300	2024	Erosion of natural deposits; water softening

Radiological						
Alpha Emitters*	pCi/L	0	15	1.9	2023	Erosion of natural deposits
Combined Radium*	pCi/L	0	5	ND - 0.5	2021, 2023	Erosion of natural deposits

Organics						
2,4-D*	ppb	70	70	ND - 0.2	2024	Runoff from herbicide used on row crops.
Xylenes*	ppm	10	10	ND - 0.0006	2024	Discharge from petroleum factories; discharge from chemical factories

Disinfectant / Disinfection Byproducts							
Water Quality Constituent	Units	MCLG (MRDLG)	MCL (MRDL)	Average Level Detected (HLRAA)	Range of Levels Detected	Sample Year	Typical Source of Detected Constituent
Chlorine Residual	ppm	(4)	(4)	1.1	0.67 - 1.4	2024	Drinking water disinfection
Haloacetic Acids	ppb	NA	60	(11)	ND - 31	2024	Byproduct of drinking water disinfection
Total Trihalomethanes	ppb	NA	80	(53)	ND - 88	2024	Byproduct of drinking water disinfection

PFAS							
Water Quality Constituent	Units	MCLG	MCL	Average Level Detected	Range of Levels Detected	Sample Year	Typical Source of Detected Constituent
Perfluorobutanoic Acid (PFBA)	ppt	NS	NS	0**	ND - 7.0	2023, 2024	Man-made substance used in surface coatings and protectant formulations; runoff from fire training/response sites, industrial sites, landfills and wastewater treatment plants

Additional Constituents (Unregulated)							
Lithium	ppb	NS	NS	94 **	49 - 176	2024	Erosion of natural deposits; industrial processes; discharge from battery production; leaching from septic tanks, sewage

Lead and Copper Monitoring							
Water Quality Constituent	Units	MCLG	Action Level	90 th Percentile of Sample Results	Number of Samples That Exceeded the Action Level	Sample Year	Typical Source of Detected Constituent
Copper	ppm	1.3	1.3	0.22	0	2024	Internal corrosion of household water plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead	ppb	0	15	ND	0	2024	Internal corrosion of household water plumbing systems; erosion of natural deposits

* Includes results from samples taken by Arizona Water Company and EPCOR. In some cases, samples collected by EPCOR exceeded regulatory limits in EPCOR's water system. All samples in Arizona Water Company's water system were below regulatory limits.

** Average of samples collected for regulatory purposes. Unregulated contaminant monitoring helps EPA to determine where certain contaminants occur and whether the Agency should consider regulating those contaminants in the future.

Your drinking water complies with the United States Environmental Protection Agency's ("USEPA") safe drinking water standard for arsenic, though it contains low levels of arsenic. USEPA's safe drinking water standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. USEPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant, you should ask advice from your health care provider.

Arizona Water Company is publishing this notice to inform its customers about the presence of Per- and Polyfluoroalkyl Substances ("PFAS") in drinking water. The test dates and test results are shown in the table above. Water systems have until 2029 to comply with PFAS chemical MCLs; wells with levels of PFAS chemicals above standards were not used to serve water to customers since 2023.

The Lead Service Line Inventory for this system has been prepared and can be viewed online via an interactive map at: <https://lead-service-line-inventory-4-azwaterco.hub.arcgis.com/>.

Note: In addition to the constituents listed in this report, Arizona Water Company conducted monitoring for over 80 additional constituents and the results show none of those constituents were detected in the water. Data presented are from the most recent testing done in accordance with applicable regulations. Some constituents are monitored less frequently than once a year because either their concentrations do not change frequently, or they are not likely to be detected. Therefore, some of the water quality testing data contained herein, although representative, may be more than one year old. If you have questions about this water quality report please contact the Environmental Compliance Manager, Arizona Water Company, P.O. Box 29006, Phoenix, Arizona 85038-9006; telephone (602) 240-6860 or email mail@azwater.com. If you have a question, concern or suggestion about your water system, please contact our local office at 623-246-7570."

In 2004, ADEQ completed a Source Water Assessment of the water sources used by Arizona Water Company's White Tank water system. ADEQ reviewed the adjacent land uses that may pose a potential risk to the water sources. The result of the Assessment was a low risk to the water sources. The complete Assessment is available for inspection at ADEQ, 1110 West Washington Street, Phoenix, Arizona 85007, between the hours of 8:00 a.m. and 5:00 p.m. Electronic copies are available from ADEQ at recordscenter@azdeq.gov. For more information, visit ADEQ's Source Water Assessment and Protection Unit website at: www.azdeq.gov/node/735.

The USEPA and ADEQ require Arizona Water Company to provide the following information:

Arizona Water Company is required to monitor your drinking water for specific contaminants on a regular basis to comply with safe drinking water standards. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. In the first quarter of 2024, Arizona Water Company did not monitor for compliance for arsenic at one site. Therefore, we received a violation for missed monitoring of arsenic and therefore cannot be sure of the quality of our drinking water during that time. However, Arizona Water Company did collect 10 operational samples for arsenic analysis at this site during the second quarter of 2024. These samples indicated that arsenic levels at this site were below the Maximum Contaminant Level of 10 parts per billion as dictated by USEPA. Your water consistently complies with safe drinking water standards. There is nothing you need to do at this time.

Please share this information with other people who drink the water, especially those who may not have received this notice directly (for example, people in a apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This is an alert about your drinking water and a cosmetic dental problem that might affect children under nine years of age. At low levels, fluoride can help prevent cavities, but children drinking water containing more than 2 milligrams per liter (mg/l) of fluoride may develop cosmetic discoloration of their permanent teeth (dental fluorosis). The drinking water provided by your community water system has a fluoride level ranging from 0 to 2.6 mg/l.

Dental fluorosis in its moderate or severe forms may result in a brown staining and or pitting of the permanent teeth. This problem occurs only in developing teeth, before they erupt from the gums. Children under nine should be provided with alternative sources of drinking water or water that has been treated to remove the fluoride to avoid the possibility of staining and pitting of their permanent teeth. You may also want to contact your dentist about proper use by young children of fluoride-containing products. Older children and adults may safely drink the water.

*Drinking water containing more than 4 mg/l of fluoride (the USEPA's drinking water standard) can increase your risk of developing bone disease. Your drinking water **does not contain more than 4 mg/l of fluoride**, but we're required to notify you when we discover that the fluoride levels in your drinking water exceed 2 mg/l because of this cosmetic problem.*

Some home water treatment units are also available to remove fluoride from drinking water. To learn more about available home water treatment units, you may call NSF International at 1-877-8-NSF-HELP.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some constituents. The presence of constituents does not necessarily indicate that water poses a health risk. More information about constituents and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to constituents in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial constituents are available from the Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radiological material, and can pick up substances resulting from the presence of animals or from human activity.

Constituents that may be present in source water include:

- Microbials, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganics, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organics, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production. They can also come from gas stations, urban stormwater runoff, and septic systems.
- Radiological material, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, USEPA prescribes regulations which limit the amount of certain constituents in water provided by public water systems. FDA regulations establish limits for constituents in bottled water which must provide the same protection for public health.

Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. Arizona Water Company is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are concerned about lead in your water and wish to have your water tested, contact Arizona Water Company, P.O. Box 29006, Phoenix, Arizona 85038-9006; telephone (602) 240-6860 or email mail@azwater.com. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.

DEFINITIONS, ABBREVIATIONS, AND UNIT DESCRIPTIONS:

Action Level (AL)	=	The concentration of a constituent which, if exceeded, triggers treatment or other requirements which a water system must follow
CDC	=	United States Centers for Disease Control and Prevention
FDA	=	United States Food and Drug Administration
HI	=	The Hazard Index is an approach that determines the health concerns associated with mixtures of certain PFAS in finished drinking water
HLRAA	=	Highest Locational Running Annual Average
MCL	=	Maximum Contaminant Level, the highest level of a constituent that is allowed in drinking water. MCLs are set as close to the MCLGs using the best available treatment technology as is economically and technologically feasible.
MCLG	=	Maximum Contaminant Level Goal, the level of a constituent in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MRDL	=	Maximum Residual Disinfection Level, the highest level of a drinking water disinfectant allowed in drinking water. There is convincing evidence that the addition of a disinfectant is necessary for control of microbial contaminants.
MRDLG	=	Maximum Residual Disinfection Level Goal, the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial constituents.
NA	=	None adopted
ND	=	None detected
NS	=	No standard
pCi/L	=	Picocuries per liter
ppb	=	Parts per billion, or micrograms per liter ($\mu\text{g/L}$)
ppm	=	Parts per million, or milligrams per liter (mg/L)
ppt	=	Parts per trillion, or nanograms per liter (ng/L)
PWSID	=	Public Water System Identification
Treatment Technique (TT)	=	A required process intended to reduce the level of a contaminant in drinking water.