

ARIZONA WATER COMPANY

3805 N. BLACK CANYON HIGHWAY, PHOENIX, AZ 85015-5351
PHONE: (602) 240-6860 • FAX: (602) 240-6874 • TOLL FREE: (800) 533-6023 • www.azwater.com

February 24, 2026

Re: Addendum No. 1 to Proposal/Contract for 3-7404 Overfield Transmission Main

Dear Contractor:

This letter serves as Addendum No. 1 to the Proposal/Contract for the above referenced project. Addendum No. 1 addresses utility installation conflicts, vertical realignment fittings, and permitting requirements.

Utility Conflicts

Item No. 1 – Mission Parkway Telecom Conflict

A new telecommunication duct bank was installed near the same alignment on Mission Parkway as the proposed water main between stations 50+00 and 85+00. Contractor must install water main inside public right-of-way, which is only dedicated on the west side of Mission Parkway. The Contractor must install the water main outside of pavement were reasonably practicable. The Contractor must install the water main in a separate trench alignment than the telecommunication duct bank.

Item No. 2 – Cottonwood Lane Electrical Conflict

The proposed water main alignment is approaching overhead electrical poles between stations 143+88 and 167+60. The Contractor must maintain minimum 3-foot horizontal separation between edge of water main trench and power poles and must construct the water main within the proposed right-of-way.

E-MAIL: genengineering@azwater.com

Vertical Realignment Fittings

Item No. 3 – Fittings on Vertical Realignments

Vertical realignments that do not include callouts for mechanical fittings are designed as pipe deflections. The Contractor may use elbow fittings if the water main cannot be constructed at the required depth via pipe deflection. All fitting installations must comply with Company requirements for thrust blocking and mechanical joint restraints.

Permitting


Item No. 4 – Permitting Requirements

The Company is in the process of obtaining all required permits (City of Casa Grande Right-of-Way Encroachment, Kinder-Morgan Gas Line Encroachment, and HIDD Right-of-Way Encroachment). The Contractor shall provide all required information, including but not limited to insurance information, traffic control plan, and bonds, when requested by permitting agencies after Contractor selection.

For questions regarding this project, please contact Dillion Greiwe at:

Arizona Water Company
Attention: Dillion Greiwe
3805 N. Black Canyon Highway
Phoenix, AZ 85015
Phone: (602) 240-6860
Email: dgreiwe@azwater.com

Very truly yours,


Andrew J. Haas, PE

Vice President – Engineering

APPROVAL AND ACCEPTANCE

The clarifications and conditions set for the above are approved and accepted.

By _____

Company _____

Title _____

Date _____

dtg

Enclosure(s)